

Product certificate
K67559/04

Issued 2014-10-15

Replaces K67559/03

Page 1 of 3

Copper tubes

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the products supplied by


Feinrohren S.p.a.

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline

BRL-K760/04: "Copper Pipes";

as well as to:

EN 1057: "Copper and copper alloys - Seamless, round copper tubes for water and gas in sanitary and heating applications".



Bouke Meekma
Kiwa

Publication of the certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
P.O. Box 70
2280 AB RIJSWIJK
The Netherlands

Tel. +31 70 414 44 00
Fax +31 70 414 44 20
info@kiwa.nl
www.kiwa.nl



130823

Supplier

Feinrohren S.p.a.
Via Generale Reverberi 8
25050 PASSIRANO (BS)
Italy
Tel. +33 030-6549011
Fax +33 030-6549300
info@feinrohren.it
www.feinrohren.it

Certification process consists of initial and regular assessment of:

- quality system
- product

Copper tubes

PRODUCT SPECIFICATION

The products mentioned below belong to this certificate.

Soft copper tubes (R220)

- 10x1,00 mm
- 12x 0,8¹ mm
- 12x1 mm
- 15x0,8¹ mm
- 15x1,0 mm
- 18*1,0 mm
- 22x0,9¹ mm
- 22x1,1 mm
- 28x1,2 mm
- 35x1,5 mm

Half hard copper tubes (R250)

- 12x0,8 mm
- 12x1 mm
- 15x0,8* mm
- 15x1,0 mm
- 18*1,0 mm
- 22x0,9* mm
- 22x1,1 mm
- 28x1,0¹ mm
- 28x1,2 mm

Hard copper tubes (R290)

- 28x1¹ mm
 - 28x1,2 mm
 - 35x1,2 mm
 - 35x1,5 mm
 - 42x1,2 mm
 - 42x1,5 mm
 - 54x1,5 mm
-

Copper tubes

APPLICATION AND USE

The products are intended to be applied in drinking water installations for the transport of hot and cold water.

TOXICOLOGICAL REQUIREMENTS

Approval:



This product is approved on the basis of the requirements set in the "Regeling materialen en chemicaliën leidingwatervoorziening" ("Regulation Materials and Chemicals for Drinking Water Supplies"), published in the "Staatscourant" (Government Gazette).

ATA criteria:

The ATA product certification is based on two main criteria. It should permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is laid down in, for confidentiality reasons, the undisclosed appendix to the Kiwa certificate K67559. This recipe is not to be changed without prior approval by Kiwa, according to the Kiwa-ATA-approval procedure;
- Specific ATA-product requirements have been laid down in the appendix to the Kiwa certificate K67559. For confidentiality reasons, this appendix is not public.

MARKING

The Kiwa[®]-mark products are marked with the word mark "KIWA  or the abbreviated work mark .

Place of the mark: on the outside of the copper tube at a distance not exceeding 0,6 m.

Compulsory specifications:

- number of the European Standard (EN 1057);
- manufacturer's identification mark;
- date of production: year and quarter (I to IV) or year and month (1 to 12);
- nominal cross-sectional dimensions: outside diameter x wall thickness;
- identification for R250 (half hard) material condition by the following symbol: I-I-I.

Method of marking:

- non-erasable;
- visible after assembly.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Feinrohren S.p.a.
and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.